

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE		PAGE 1 OF 3 PAGES		
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 14 January 2004		4. REQUISITION/PURCHASE REQ. NO. SP0600-04-0653		5. PROJECT NO. (If applicable) State of Washington	
6. ISSUED BY CODE		SP0600		7. ADMINISTERED BY (If other than Item 6) CODE			
ATTN: BEVERLY WILLIAMS DEFENSE ENERGY SUPPORT CENTER 8725 JOHN J. KINGMAN RD., SUITE 2945 FORT BELVOIR, VA 22060-6222 PHONE: 703-767-9348 EMAIL: beverly.j.williams@dla.mil FAX: 703-767-9338							
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X) 9A. AMENDMENT OF SOLICITATION NO. SP0600-04-R-0014 X 9B. DATED (SEE ITEM 11) 6 November 2003 10A. MODIFICATION OF CONTRACT/ORDER NO. 10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					

### 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If required)

### 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X) A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc). SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☒ is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

SEE PAGES 2 THROUGH 3

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

1. The above-referenced solicitation is hereby issued to update Clause E18. Clause E18 is as follows:

**E18 INSPECTION AND CLEANING OF BULK PETROLEUM STORAGE TANKS (DESC NOV 2003)**

(a) The Contractor shall maintain and make available upon request the following historical data relative to each storage tank provided:

- (1) Date and type of construction;
- (2) Name of installing contractor;
- (3) Product service (past and present) and dates;
- (4) Date of last cleaning/physical entry inspection and contractor's name;
- (5) Structural condition based on cycle inspection at the time of cleaning or repair;
- (6) Record of tank repairs;
- (7) Tank dimensions and capacity;
- (8) Inspection and tank cleaning frequency (date of next mandatory inspection, when tank out of service, required);
- (9) Tank coating history;
- (10) Tank strapping charts;
- (11) As built drawings (if available); and
- (12) Records of product tests and trends.

(b) At the Contractor's expense, the Contractor shall empty, inspect, and clean each bulk petroleum storage tank and dispose of all tank bottom waste for each tank furnished under this contract at the following intervals. When tank cleaning does take place, the Contractor, at his own expense, shall be responsible for providing alternate tankage and transferring the remaining product to that tankage. Such tankage shall be suitable for storing the transferred product and shall be of equal or greater capacity than the tankage being cleaned. Any proposed reduction in the storage capacity cited in the contract must be approved by the Contracting Officer in advance.

**(1) AVIATION FUEL STORAGE TANKS.**

- (i) Every 4 years for uncoated storage tanks without an inlet-filter separator;
- (ii) Every 6 years for either a coated tank without an inlet filter separator, or for an uncoated tank with an inlet-filter separator; and

(iii) Every 8 years for coated tanks with an inlet-filter separator.

*(iv) For storage tanks with direct receipt of fuel from barge or tanker, the frequency for physical entry inspection and cleaning will be 3, 5, and 8 years for (i), (ii), and (iii) above, respectively.*

(v) Tanks will be emptied, cleaned, and inspected more frequently than the periods stated in (i) through (iv) above when sample analysis indicates a build up of sediment in the tanks.

**(2) GROUND AND MARINE FUEL STORAGE TANKS.** Tanks will be emptied, cleaned, and inspected when sample analysis indicates a build up of sediment in the storage tanks.

(c) The time for cleaning will be measured from the date of the last cleaning regardless of whether the tank was under contract with DESC at the time of the last cleaning.

(d) Samples will be taken and tested at Government expense. If tank cleaning is required earlier than the criteria listed in (b)(1) above and the Government is shown to be at fault, then the Government will be responsible for cleaning, sampling, and testing costs. In all other cases, tanks requiring cleaning will be removed from revenue and cleaned at the Contractor's expense.

(e) At the time of offer submission, the offeror shall provide the Contracting Officer with a listing of all tank inspections and cleanings, and other activities that would take a tank out of service, which are anticipated to occur during the contract period (see chart below). This listing shall include the tank number, location, reason for being out of service, dates the tank will be out of service and provisions that have been made to replace the tankage while it is out of service. Updates to the listing shall be sent to the Contracting Officer as soon as a change is known.

(DESC 52.246-9FF1)

2. All other terms and conditions remain unchanged.